



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE  
PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	7300-0713:0107
<b>PARENT LISTING No.:</b>	7300-1609:0100
<b>CATEGORY:</b>	7300 - FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES
<b>LISTEE:</b>	COOKSON 24 Elmwood Avenue, Mountain Top, PA, 18707 Contact: Mikleton, Nathan 5705507156 Email: nathan.mikleton@cornellcookson.com
<b>DESIGN:</b>	Models Firefly III, Firefly III Plus, Firefly III Plus with Voiceboard , Test A Fire III, and Test A Fire III with Voiceboard releasing devices. All units are intended to be used in conjunction with a temperature fusible link system to release a maximum 40 lbs. door load. Refer to listee's data sheet for additional detailed product description and operational considerations.
<b>RATING:</b>	Firefly III: 24 VDC Firefly III Plus: 120 VAC, 24 VAC, 24VDC Firefly III Plus with Voiceboard: 120 VAC, 24 VAC, 24 VDC Test A Fire III: 120 VAC Test A Fire III with Voiceboard: 120 VAC
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to authority having jurisdiction.
<b>MARKING:</b>	Listee's name, model number, electrical rating and UL label.
<b>APPROVAL:</b>	Listed as releasing devices. For indoor use only. Authority having jurisdiction shall be consulted prior to installation.
<b>NOTES:</b>	

11-15-06 KV



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE  
PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 06/23/2025**

**Listing Expires: 06/30/2026**

Authorized By: **Michael Huang** , Program Coordinator  
Fire Engineering & Investigations Division