

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



# LISTING SERVICE

**LISTING No.** 7300-0713:0107 Page 1 of 1

**CATEGORY:** 7300 -- FIRE ALARM CONTROL UNIT ACCESSORIES/MISC. DEVICES

**LISTEE:** COOKSON24 Elmwood Avenue, Crestwood Industrial Park, Mountain Top, PA 18707  
Contact: Jim Dever (570) 474-6773 Ext: 4526 Fax (866) 448-6798  
Email: jim.dever@cornellcookson.com

**DESIGN:** Models Firefly III, Firefly III Plus, Firefly III Plus with Voiceboard , Test A Fire III, and Test A Fire III with Voiceboard releasing devices. All units are intended to be used in conjunction with a temperature fusible link system to release a maximum 40 lbs. door load. Refer to listee's data sheet for additional detailed product description and operational considerations.

**RATING:** Firefly III = 24 VDC  
Firefly III Plus = 120 VAC, 24 VAC, 24VDC  
Firefly III Plus with Voiceboard = 120 VAC, 24 VAC, 24 VDC  
Test A Fire III = 120 VAC  
Test A Fire III with Voiceboard = 120 VAC

**INSTALLATION:** In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to authority having jurisdiction.

**MARKING:** Listee's name, model number, electrical rating and UL label.

**APPROVAL:** Listed as releasing devices. For indoor use only. Authority having jurisdiction shall be consulted prior to installation.

**XLF:** 7300-1609:0100

11-15-06 KV



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2019**

Listing Expires **June 30, 2020**

Authorized By: **DAVID CASTILLO, Program Coordinator**  
*Fire Engineering Division*