



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE
PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	4077-0713:0503
PARENT LISTING No.:	4077-0550:0501
CATEGORY:	4077 - FIRE PROTECTIVE CURTAIN
LISTEE:	COOKSON 24 Elmwood Avenue, Mountain Top, PA, 18707 Contact: Mikleton, Nathan (570) 550-7156 Email: nathan.mikleton@cornellcookson.com
DESIGN:	Model ERF 20 SmokeShield Fabric Fire and Smoke Doors, Standard Fire-Protective Curtain. Refer to listee's data sheet for detailed product description and operational considerations.
RATING:	Up to and including 3 hr. fire rating
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, model number, and UL label.
APPROVAL:	Listed as a fire-protective curtain in gypsum or masonry walls for nonstructural applications where no hose stream requirements exists. Authority having jurisdiction should be consulted prior to installation. Refer to listee's Installation Instructions Manual for details.
NOTES:	Test Std. UL 10D and UL 1784

06-05-18 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/07/2023

Listing Expires: 06/30/2024



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE
PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

Authorized By: **Victor Wong** , Program Coordinator
Fire Engineering & Investigations Division