

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM



LISTING SERVICE

LISTING No. 4077-0713:0503 Page 1 of 1

CATEGORY: 4077 -- FIRE PROTECTIVE CURTAIN

LISTEE: COOKSON24 Elmwood Avenue, Crestwood Industrial Park, Mountain Top, PA 18707
Contact: Nathan Mikleton (570) 550-7156
Email: nathan.mikleton@cornellcookson.com

DESIGN: Model ERF 20 SmokeShield Fabric Fire and Smoke Doors, Standard Fire-Protective Curtain.
Refer to listee's data sheet for detailed product description and operational considerations.

RATING: Up to and including 3 hr. fire rating

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances, and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, and UL label.

APPROVAL: Listed as a fire-protective curtain in gypsum or masonry walls for nonstructural applications where no hose stream requirements exists. Authority having jurisdiction should be consulted prior to installation. Refer to listee's Installation Instructions Manual for details.

NOTE: Test Std. UL 10D and UL 1784

XLF: 4077-0550:0501

06-05-18 gt



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other

Date Issued: **July 01, 2021**

Listing Expires **June 30, 2022**

Authorized By: **DAVID CASTILLO, M.E., F.P.E.**
Fire Engineering Division