



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE  
PROTECTION  
OFFICE OF THE STATE FIRE MARSHAL  
FIRE ENGINEERING & INVESTIGATIONS DIVISION  
BUILDING MATERIALS LISTING PROGRAM**

**LISTING SERVICE**

<b>LISTING No.:</b>	3505-0713:0109
<b>PARENT LISTING No.:</b>	3505-0550:0108
<b>CATEGORY:</b>	3505 - SERVICE COUNTER DOOR (FIRE-RATED)
<b>LISTEE:</b>	COOKSON 24 Elmwood Avenue, Mountain Top, PA, 18707 Contact: Mikleton, Nathan 5705507156 Email: nathan.mikleton@cornellcookson.com
<b>DESIGN:</b>	Mineral core countertop with plastic laminated surface. Core consists of two layers of 3/4" vermiculite boards. Plastic laminate max. 0.05". Refer to listee's data sheet for detailed product description and operational considerations.
<b>RATING:</b>	1-1/2 hr.
<b>INSTALLATION:</b>	In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.
<b>MARKING:</b>	Listee's name, fire rating and UL label.
<b>APPROVAL:</b>	Listed as a fire rated countertop for use with rolling steel type and service counter type fire doors rated up to 1-1/2 hrs. Refer to listee's Installation Instructions Manual for details.
<b>NOTES:</b>	

08-03-15 gt



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

**Date Issued: 06/26/2025**

**Listing Expires: 06/30/2026**

Authorized By: **Michael Huang** , Program Coordinator  
Fire Engineering & Investigations Division