



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE
 PROTECTION
 OFFICE OF THE STATE FIRE MARSHAL
 FIRE ENGINEERING & INVESTIGATIONS DIVISION
 BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

LISTING No.:	3505-0713:0501
PARENT LISTING No.:	3505-0550:0105
CATEGORY:	3505 - SERVICE COUNTER DOOR (FIRE-RATED)
LISTEE:	COOKSON 24 Elmwood Avenue, Mountain Top, PA, 18707 Contact: Mikleton, Nathan 5705507156 Email: nathan.mikleton@cornellcookson.com
DESIGN:	<p>Cookson models ERC 10, ERC 11, ERC 20, ERC 21 Steel or Stainless steel service counter type fire door. Unit consists of integral guides, anchors, a curtain, barrel assembly, automatic releasing mechanism and counterbalance springs installed in drywall or masonry walls.</p> <p>Curtain Assembly: Consists of slats, alternating end-locks, a bottom bar and guides</p> <p>Slats: No. 22 gauge, type 304 steel or stainless steel, 1-1/4" width by 1/2" depth</p> <p>Bottom Bar: One 1-1/2" by 1-1/2" steel angle</p> <p>Guides: Integral with side jambs</p> <p>Hood: No. 16 Gauge stainless steel</p> <p>Refer to listee's data sheet for detailed product description and operational considerations.</p>
RATING:	1-1/2 hr. or 3/4 hr.
INSTALLATION:	In accordance with listee's printed installation instructions, applicable codes & ordinances and in a manner acceptable to the authority having jurisdiction.
MARKING:	Listee's name, classification and UL label.
APPROVAL:	Listed as service counter type fire rated door with integral frame designed for the protection of openings in walls for 1-1/2 hr. or 3/4 hr. locations. Wall opening shall not exceed 6'4" high and 10'10" wide.
NOTES:	



**CALIFORNIA DEPARTMENT OF FORESTRY & FIRE
PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING & INVESTIGATIONS DIVISION
BUILDING MATERIALS LISTING PROGRAM**

LISTING SERVICE

12-2-2016 dc



This listing is based upon technical data submitted by the applicant. OSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: 06/26/2025

Listing Expires: 06/30/2026

Authorized By: **Michael Huang** , Program Coordinator
Fire Engineering & Investigations Division